

Comment 1

29-12-04 9:12pm

Name: Axel Michaelowa	City: Hamburg
Organisation: Hamburg Institute	Country: Germany
<p>Both operating and build margin factor are calculated on shaky assumptions about the efficiencies of the thermal power plants (no source given, values apparently rounded off to the next 5%). The actual efficiencies of each power station have to be used based on fuel input and generation.</p>	